

FR_718058

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE Product Li-ion battery Pack Series Stacking LFP Li-ion Battery System Name and address of the applicant Shenzhen Voltsmile Energy Technology Co.,Ltd 1st Building Excellence Times Square, Level 26, 4068 Yitian Road, Futian District, Shenzhen, 518000 Guangdong Province - CHINA Name and address of the manufacturer Huizhou Voltsmile Energy Technology Co.,Ltd 4th Floor, Factory 3, Minhua Smart Home Drive System Park, No. 433 Xinhe Avenue, Daya Bay West District Huizhou, Guangdong Province - CHINA Huizhou Voltsmile Energy Technology Co.,Ltd Name and address of the factory 4th Floor, Factory 3, Minhua Smart Home Drive System Park, No. 433 Xinhe Avenue, Daya Bay West District Huizhou, Guangdong Province - CHINA Note: When more than one factory, please report on page 2 ☐ Additional Information on page 2 Ratings and principal characteristics See Annex Trademark / Brand (if any) Customer's Testing Facility (CTF) Stage used Model / Type Ref. See Annex Additional information (if necessary may also be ☐ Additional Information on page 2 reported on page 2) A sample of the product was tested and found to IEC 62619:2022 be in conformity with As shown in the Test Report Ref. No. which CNDQ-ESH-P23110676 forms part of this Certificate



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE 33 avenue du Général Leclerc 92260 Fontenay-aux-Roses, FRANCE

This CB Test Certificate is issued by the National Certification Body

www.lcie.fr

Date: 01/12/2023



Certification Officer



FR_718058

ANNEX

References, ratings and main characteristics:

Model	Rated Voltage (V)	Rated Capacity (Ah)	Rated Power (kWh)
H1-12	614.4	100	61.44
H1-11	563.2	100	56.32
H1-10	512	100	51.2
H1-9	460.8	100	46.08
H1-8	409.6	100	40.96
H1-7	358.4	100	35.84
H1-6	307.2	100	30.72
H1-5	256	100	25.6
H1-4	204.8	100	20.48
H1-3	153.6	100	15.36
H1-2	102.4	100	10.24



Date: 01/12/2023

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE 33 avenue du Général Leclerc 92260 Fontenay-aux-Roses, FRANCE www.lcie.fr

LCIE

LABORATOIRE CENTBAL DES
NATURES ELLECTRIQUES
S.A.S. ar capital de 15.745 984 €
RCS Nature 15.745 984 €
RCS Nature 15.745 984 €
Certification Tofficer Roses